



Electrical Service Panel Checklist

- Grounding: Inside panel and building**
- Safe wiring**
- Proper torques on all points of contact**
- Water damage**
- Oxidation on equipment or wires**
- Openings in equipment boxes**
- Overloaded amperage of circuits**
- Load calculations**
- Proper connections**
- Appropriate gauge wire for circuits**
- Phased correctly and identified**
- Bus discoloration**
- Debris in panel box**



Electrical Service Panel Checklist

- Waterproofing exposed gaps**

- Fire blocking from outside to inside**

- Readily identified and labeled shut-off**

- Surge protection**

- GFCI breakers operational and tested**

- Tight fittings and sealed external holes**

- Service equipment accessible, per code**

- Panel schedule labeled**

- Thermal scanning**

-
-
-
-
-